

# 2014 WATER QUALITY REPORT FOR POLK CITY WATER SUPPLY

This report contains important information regarding the water quality in our water system. The source of our water is surface water and groundwater. Some of the water is purchased. Purchased water comes from Des Moines Water Works. Our water quality testing shows the following results:

CONTAMINANT	MCL - (MCLG)	Compliance		Date	Violation	Source
		Type	Value & (Range)			
Total Trihalomethanes (ppb) [TTHM]	80 (N/A)	LRAA	45.00 (41 - 48)	09/30/2014	No	By-products of drinking water chlorination
Total Haloacetic Acids (ppb) [HAA5]	60 (N/A)	LRAA	21.00 (13 - 27)	12/31/2014	No	By-products of drinking water disinfection
Lead (ppb)	AL=15 (0)	90th	3.70 (ND - 5)	2013	No	Corrosion of household plumbing systems; erosion of natural deposits
Copper (ppm)	AL=1.3 (1.3)	90th	0.732 (0.0361 - 1.010)	2013	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
<b>950 - DISTRIBUTION SYSTEM</b>						
Chlorine (ppm)	MRDL=4.0 (MRDLG=4.0)	RAA	.71 (0.31 - 1.50)	12/31/2014	No	Water additive used to control microbes
Fluoride (ppm)	4 (4)	RAA	0.77 (0.46 - 1.77)	12/31/2014	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
<b>01 - AFTER WTP AND DMWW</b>						
Barium (ppm)	2 (2)	SGL	0.156	05/01/2013	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4 (4)	SGL	0.6	05/01/2013	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Sodium (ppm)	N/A (N/A)	SGL	16.2	05/01/2013	No	Erosion of natural deposits; Added to water during treatment process
Nitrate [as N] (ppm)	10 (10)	SGL	2.500	2014	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Note: Contaminants with dates indicate results from the most recent testing done in accordance with regulations.

## DEFINITIONS

- Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG) -- The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ppb -- parts per billion.
- ppm -- parts per million.
- pCi/L – picocuries per liter
- N/A – Not applicable
- ND -- Not detected
- RAA – Running Annual Average

- LRAA – Locational Running Annual Average
- Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.
- Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- SGL – Single Sample Result
- TCR – Total Coliform Rule
- NTU – Nephelometric Turbidity Units

**GENERAL INFORMATION**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water posed a health risk. More information about contaminants or potential health effects can be obtained by calling the Environmental Protection Agency’s Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. POLK CITY WATER SUPPLY is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

**SOURCE WATER ASSESSMENT INFORMATION**

This water supply obtains its water from the buried sand and gravel of the Buried Sand and Gravel aquifer. The Buried Sand and Gravel aquifer was determined to be highly susceptible to contamination because the characteristics of the aquifer and overlying materials provide little protection from contamination at the land surface. The Buried Sand and Gravel wells will be highly susceptible to surface contaminants such as leaking underground storage tanks, contaminant spills, and excess fertilizer application. A detailed evaluation of your source water was completed by the Iowa Department of Natural Resources, and is available from the Water Operator at 515-984-6035.

This water supply obtains some or all of its water from another public water supply. It is a consecutive water supply, where an originating parent supply provides drinking water to one or more downstream supplies.

Original Supply ID	Original Supply Name
IA7727031	Des Moines Water Works

**OTHER INFORMATION**

Turbidity is an indicator of treatment filter performance and is regulated as a treatment technique.

**CONTACT INFORMATION**

For questions regarding this information or how you can get involved in decisions regarding the water system, please contact POLK CITY WATER SUPPLY at 515-984-6035.

**PURCHASED WATER INFORMATION**

Our water system purchases water from the system(s) shown below. Their water quality is as follows:

CONTAMINANT	MCL - (MCLG)	Compliance		Date	Violation	Source
		Type	Value & (Range)			
<b>7727031 - DES MOINES WATER WORKS</b>						
<b>03 - MCMULLEN AFTER TREATMENT</b>						
Fluoride (ppm)	4 (4)	SGL	0.67	04/02/2012	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Sodium (ppm)	N/A (N/A)	SGL	19.2	04/07/2014	No	Erosion of natural deposits; Added to water during treatment process
Nitrate [as N] (ppm)	10 (10)	SGL	7.93 (0.59 - 7.93)	2014	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
<b>04 - RACCOON, DES MOINES, &amp; GALLERY FLEUR</b>						
Gross Alpha, inc (pCi/L)	15 (0)	SGL	1.6	02/24/2010	No	Erosion of natural deposits
Fluoride (ppm)	4 (4)	SGL	0.67	04/02/2012	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Sodium (ppm)	N/A (N/A)	SGL	36.5	04/07/2014	No	Erosion of natural deposits; Added to water during treatment process
Nitrate [as N] (ppm)	10 (10)	SGL	8.17 (0.89 - 8.17)	2014	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
<b>05 - LP MOON ASR S/EP AFTER TREATMENT</b>						
Sodium (ppm)	N/A (N/A)	SGL	36.8	07/09/2014	No	Erosion of natural deposits; Added to water during treatment process
Nitrate [as N] (ppm)	10 (10)	SGL	1.76 (0.96 - 1.76)	2014	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
<b>06 - MCMULLEN ASR S/EP</b>						
Sodium (ppm)	N/A (N/A)	SGL	16.2	07/30/2014	No	Erosion of natural deposits; Added to water during treatment process
Nitrate [as N] (ppm)	10 (10)	SGL	6.93 (0.57 - 6.93)	2014	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
<b>07 - SAYLORVILLE S/EP (AFTER TREATMENT)</b>						
Fluoride (ppm)	4 (4)	SGL	0.24	03/25/2011	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Barium (ppm)	2 (2)	SGL	0.1	02/25/2011	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Sodium (ppm)	N/A (N/A)	SGL	23.2	02/10/2014	No	Erosion of natural deposits; Added to water during treatment process
Nitrate [as N] (ppm)	10 (10)	SGL	2.44 (0.08 - 2.44)	2014	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Turbidity (NTU)	N/A (N/A)	TT	Enter highest single measurement and the lowest monthly percentage of samples meeting turbidity limits here.			Soil runoff

